



PLEASE CONTINUE TO FOLLOW THE POSTED BOIL WATER ADVISORY INSTRUCTION. THIS WATER WELL IS NOT FOR DRINKING WATER USE.

## TEST RESULTS

**REPORTED TO PROJECT** Yellowhead County Well Testing

**WORK ORDER REPORTED** 2210662  
2022-09-09 17:30

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
<b>Gregg Lake Sept (2210662-01)   Matrix: Water   Sampled: 2022-09-06 10:41</b>						
<i>Microbiological Parameters</i>						
Coliforms, Total (Q-Tray)	25	MAC = 0	1	MPN/100 mL	2022-09-08	
E. coli (Q-Tray)	< 1	MAC = 0	1	MPN/100 mL	2022-09-08	