

## TEST RESULTS

REPORTED TO Yellowhead County  
PROJECT Lagoon Drain

WORK ORDER 25A1474  
REPORTED 2025-01-17 11:45

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
<b>Gregg Lake (25A1474-01)   Matrix: Water   Sampled: 2025-01-15 12:12</b>						
<i>Microbiological Parameters</i>						
Coliforms, Total (Q-Tray)	< 1	MAC = 0	1	MPN/100 mL	2025-01-17	
E. coli (Q-Tray)	< 1	MAC = 0	1	MPN/100 mL	2025-01-17	