TEST RESULTS

REPORTED TO	Yellowhead County	**WORK ORDER**	26D1364
PROJECT	Well Testing	**REPORTED**	2026-04-15 11:50

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
Gregg Lake (26D1364-01) | Matrix: Water | Sampled: 2026-04-13 13:30						
Microbiological Parameters						
Coliforms, Total (Q-Tray)	< 1	MAC = 0	1	MPN/100 mL	2026-04-15	
E. coli (Q-Tray)	< 1	MAC = 0	1	MPN/100 mL	2026-04-15	